



Roxbury Water Company completed our routine Lead sampling in June of 2015. Below are the results for your reference. We are well below the state required action level of 15 parts per billion. If you have any questions or concerns, please call our office at 973.584.4118.

*Action level 15 parts per billion (0.015)*

**Well 1A – Eyland Avenue – 0.000160 B**

**Well 3A – Dell Avenue – 0.000860 B**

**Well 5 – Reger Road – 0.000840 B**

**Well 7A – Pleasant Village Drive – 0.000570 B**

**Well 8 – Wright Court – 0.000420 B**